

STEP- presentation 04.03.2021:

**Effects on WWTP efficiency of reducing
excess water from sewers.**

**Modelling Rønne WWTP on energy
consumption, nutrient outflow, and
sludge**

by
Torben Jørgensen
BEOF

STEP :
Sludge Technological Ecological Progress -
increasing the quality and reuse of sewage
sludge

Project-partners

- Electrical Engineering Faculty, West Pomeranian University of Technology, Szczecin (lead);
- Goleniow Water and Sewage Compagny;
- Mittskåne Vatten, Höörs Kommun;
- Klaipeda University;
- Bornholms Energi og Forsyning (BEOF)



SLUDGE TECHNOLOGICAL ECOLOGICAL PROGRESS

increasing the quality and reuse of sewage sludge

Slide 0: Preface

Slide 1: Index:

Slide 2: Bornholm / BEOF

Slide 3: Bornholms Wastewater A/S / Bornholm

Slide 4: Excess water issues

Slide 5: Expected effects of reducing excess water

Slide 6-9: Modelling Rønne WWTP

Slide 10-13: Results

Slide 14: Conclusions

Slide 15: Key figures – Rønne WWTP



BEOF = Bornholms Energy & Supply - Holding company for six utility companies

- Bornholms Water
- **Bornholms Wastewater**
- Bornholms Heat
- Bornholms Power Production
- Bornholms Energy (Power retail)
- Bornholms Power grid

100 % owned by the municipality of Bornholm



Rønne city, harbor, and Power Plant



SLUDGE TECHNOLOGICAL ECOLOGICAL PROGRESS

increasing the quality and reuse of sewage sludge

Bornholms Wastewater A/S

- Runs the public sewers and WWTPs on Bornholm
- Svaneke and Boderne WWTP: each 4.500 PE
- Nexø and Tejn WWTP: each 10.000 PE
- **Rønne WWTP: 60.000 PE – build in 1995**

Factsheet Bornholm

Population app. 40.000

Area: 589 km²

Coastline: 158 km

North to South: 40 km

East to West: 30 km

Swedish coast: 37 km

Poland: 90 km

Denmark: 135 km



Excess water issues

Excess water is:

- Rainwater mixed with wastewater – mostly from city centers with no separation
- Groundwater that enters old sewers through cracks, and joints
- Water from drains, ditches, or small streams, that is connected by mistake, or connected before the WWTPs was build in the early 1990' (in Denmark)

Excess water issues:

- Reduces the efficiency of WWTPs - every m3 in outlet has a small concentration of nutrients, organic matter and micropollutants
- Overflow from sewer systems directly to recipient during and after heavy rain



Expected effects of reducing excess water

Before modelling we expected these effects of reducing excess water:

- Reduced total amount of N, P and BOD in outlet, proportional to reduction of excess water
- A small increase in sludge production, with increased amounts of N and P
- Reduced energy consumption, mostly for pumping and generating compressed air for aeration of the wastewater
- Effects on the amount of nitrous oxide (N₂O – “laughing gas”) released ?

larger Danish WWTPs must reduce the amount of N₂O release in 2025, because N₂O is app. 300 times more powerful than CO₂ as greenhouse gas



Modelling Rønne WWTP

Objective: evaluate performance of Rønne WWTP in different scenarios, regarding:


- Effluent quality (COD, N, P)
- Sludge production and composition (N, P)
- Energy use for pumping and aeration

Modelling Principles:

- Implementation of layout of Rønne WWTP in WEST (done by engineers at DHI)
- Data collection, evaluation and selection
- Characterization of influent wastewater – *from COD, N, P to model variables*
- Calibration of the model against measured data
- Scenario analysis – *changes in effluent, sludge, energy*


WEST layout of Rønne WWTP – Biological treatment

Nitro/Denitro



Reactor hydraulics


Aerated / non-aerated zones




© DHI

WEST layout of Rønne WWTP – Biological treatment

Aeration control








Line 2 - Aeration 1






Comparison with 2018 average data





Effluent COD, N and P loads






Sludge production and composition

	% extra inflow					
	0%	20%	40%	60%	80%	100%
MLSS (g/L)	4.10	4.08	4.07	4.05	4.04	4.03
Sludge production (t TS / d)	2.59	2.59	2.59	2.58	2.58	2.58
N content (% TS)	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%
P content (% TS)	2.2%	2.2%	2.2%	2.2%	2.2%	2.2%

Mixed liquor suspended solids (**MLSS**) is the concentration of suspended solids, in an [aeration](#) tank during the [activated sludge process](#)



Energy consumption





Excess water reduction = cost reduction

% Excess water	0%	20%	40%	60%	80%	100%
Pumping energy	132,356 kr.	152,206 kr.	172,055 kr.	191,905 kr.	211,755 kr.	231,604 kr.
Aeration energy	269,310 kr.	274,663 kr.	272,874 kr.	275,940 kr.	277,473 kr.	276,962 kr.
Energy costs / year	401,666 kr.	426,869 kr.	444,929 kr.	467,845 kr.	489,228 kr.	508,566 kr.
Effluent tax BOD	48,542 kr.	56,184 kr.	63,894 kr.	71,604 kr.	79,786 kr.	87,541 kr.
Effluent tax N	176,270 kr.	211,603 kr.	246,863 kr.	282,075 kr.	316,739 kr.	350,353 kr.
Effluent tax P	92,332 kr.	102,335 kr.	112,575 kr.	123,602 kr.	132,189 kr.	139,859 kr.
Effluent tax costs / year	317,144 kr.	370,122 kr.	423,332 kr.	477,281 kr.	528,714 kr.	577,753 kr.
Total yearly costs	718,810 kr.	796,991 kr.	868,261 kr.	945,126 kr.	1,017,942 kr.	1,086,319 kr.
Total yearly cost reduction 100% -> 0% excess water: 34%						
Note : The effluent tax has increased by 5,5% in 2020 = 17,41 kr./kg BOD ₅ , 31,65 kr./kg N, 174,07 kr./kg P						



Modelling Rønne WWTP- conclusions

Eliminating all excess water (accounting for 40% of average flow today) **results in:**

- 50% reduction of **N**, and 25% reduction of **P** in effluent
- No major changes in sludge production and N, P content in sludge
- 20% reduction in energy consumption, mostly related to pumping energy
- 34% reduction in costs - energy and effluent taxes

it is estimated that every 20% step in reduction of excess water will correspond to app.:

- 9%, 10% and 7% reduction in effluent BOD, N and P, respectively
- 4% reduction in energy consumption (pumping)
- 7% reduction in costs – energy and effluent taxes

See also <https://www.dhigroup.com/global/references/emea/overview/reducing-hydraulic-loading-to-maximise-efficiency>



Rønne WWTP- key figures

Key figures				Rønne	WWTP	
Belastning		2018	2017	2016	2015	2014
Vand						
Flow	m ³	2,860,675	3,190,701	2,653,190	2,953,885	2,739,798
Excess water - estimated	m ³	1,800,000				
Rain	mm	487	806	531	741	702
Belastning						
PE (COD-based)	PE	51,902	60,445	48,210	44,989	66,856
PE (BOD-based)	PE	38,173	46,360	48,191	43,925	64,227
Influent		2018	2017	2016	2015	2014
Stoffer						
COD	kg	3,089,529	2,983,305	3,065,455	2,649,408	4,212,439
BOD	kg	1,051,298	1,091,752	1,375,577	1,167,921	1,849,364
Total N	kg	159,721	141,454	164,090	155,420	273,751
Total P	kg	24,101	23,000	28,491	25,290	36,805
Efluent		2018	2017	2016	2015	2014
Flow	m ³	2,860,675	3,190,701	2,653,190	2,953,885	2,739,798
COD	kg	71,159	65,077	52,389	60,496	69,408
BOD	kg	5,984	5,380	3,929	5,265	5,875
Total N	kg	9,655	11,141	6,876	6,558	8,334
Total P	kg	898	641	490	549	583
Purification		2018	2017	2016	2015	2014
COD	%	97.7	97.8	98.3	97.7	98.4
BOD	%	99.4	99.5	99.7	99.5	99.7
Total N	%	94.0	92.1	95.8	95.8	97.0
Total P	%	96.3	97.2	98.3	97.8	98.4